

FLOOR SLIP RESISTANCE TESTING CERTIFICATE



Testing Certificate Ref No:

AW/FS/1902004

Client	F3 Group
Location	+Samples+
Date Tested	04th March 2019
Pendulum Equipment Used	KSS Pendulum
Pendulum Serial No	ST13
Pendulum Calibrated	12th November 2018
Slider Type Used (Delete as Required)	96 slider
Slider Ser No(s) - Batch	96#64
Slider Date Expiry	01st May 2019

The Pendulum was used in accordance with the United Kingdom Slip Resistance Group (UKSRG) guidelines for testing floors to ascertain the slip resistance to BS EN 14231. The tests were carried out under: -

- Wet Conditions (Using potable water to cover the whole test area and refreshed between tests).
- Dry & sunny conditions

Eight measurements were taken at each condition and in three different horizontal planes (0, 45 and 90 degrees) at each position. The first three measurements were discarded to allow checks for slider stabilisation. The median (average) of the remaining results were then calculated, as advocated by the UKSRG/Health & Safety Executive (HSE). The results for the floors tested are indicated in the table below:

The HSE / UKSRG has determined a minimum Pendulum Test Value reading of above 35 must be obtained in all conditions (Dry, Wet, or Contaminated) and on a level surface for a floor to pass the test

Ref	Area / Room	Surface Type	Ambient Temp (deg C)	Mean (Average) Reading	Pass / Fail
1	Sample	Pro GRI	22c	DRY 64	PASS
				WET 58	
				OILED 44	
2	Sample	Pro Road	22c	DRY 76	PASS
				WET 56	
				OILED 40	
3	Sample	Pro Base	22c	DRY 51	PASS
				WET 40	
				OILED 31	

Signed on behalf of FloorSlip Ltd:	<i>A. I. Wylie</i>	Name:	Andrew Wylie	Date:	04/03/19	Valid Until Date:	N/A
------------------------------------	--------------------	-------	--------------	-------	----------	-------------------	-----

This test certificate is not valid or original if the embossed company stamp is not present

FloorSlip Ltd - www.floorslip.co.uk
 e:mail - info@floorslip.co.uk
 Tel: 08719 152535 / 08713 155789



